

April 10, 2014


MicroSolar Systems Pty Ltd
4 Joyce Street
Springvale 3171

**STRUCTURAL CERTIFICATION OF PART MSSTKT-Tr
TRIANGLE ROOF MOUNT FOR SOLAR PANELS**

This is to Certify that part MSSTKT-Tr U-shaped arm, 25.5mm x 46mm x 3mm, for triangle roof mount for solar panels manufactured from aluminium alloy 6061-T6, satisfies the wind loading code AS1170.2...2011.

The spacing of supports and minimum number of supports shall be as follows for Wind Code Regions A & B, and C & D.

ROOF HEIGHT	REGION A & B	REGION C & D
5 metres	1500 (3)	720 (5)
10 metres	1400 (3)	700 (5)
15 metres	1100 (4)	620 (5)



Harry Carlin-Smith FIEAust CPEng
Managing Director